


KS1000 AWP / LPCB insulated wall panel horizontally laid

Self-drilling self-tapping primary fixings with minimum 16mm diameter non-ferrous EPDM backed washer



Note for KS1000WV Profile: 9x6mm PVC foam tape should be used instead of the noted 4mm diameter butyl rubber sealant between the face of the panel and any external flashings including vertical tophat flashings.

Notes:

Rev	Description	Chkd	Date
-----	-------------	------	------



**Insulated Roof
& Wall Panels**

enviro*care*[®]

TECHNICAL SERVICES

Kingspan Limited
Greenfield Business Park No. 2, Greenfield,
Holywell, Flintshire, CH8 7GJ, UK
www.kingspanpanels.co.uk
t: 0800 587 0090

Carrickmacross Road,
Kingscourt, Co.Cavan, Ireland
www.kingspanpanels.ie
t: 00353 42 96 98529

Client

Project

Drawing

KS1000 AWP Hz Joint

Status

Drawn by	Checked by	Date
RL	JP	11/02/15
Drawing Number		Revision
AWPHz15047		

This drawing is the property of Kingspan and may not be reproduced in any way without written consent from Kingspan.