


Option A



Note: Secondary steelwork should be continuous, however if there is any gaps between the vertical supports which are above 20mm a flashing plate should be introduced to brige the gap - refer to Kingspan Envirocare Update 49

Notes:

--	--	--	--

Rev	Description	Chkd	Date
-----	-------------	------	------



Insulated Roof  
& Wall Panels



**Kingspan Limited**  
Greenfield Business Park No. 2, Greenfield,  
Holywell, Flintshire, CH8 7GJ, UK  
www.kingspanpanels.co.uk  
t: 0800 587 0090

Carrickmacross Road,  
Kingscourt, Co.Cavan, Ireland  
www.kingspanpanels.ie  
t: 00353 42 96 98529

Client

Project

Drawing

KS1000 OPT Hz  
Option A Vert Joint

Status

Drawn by RL	Checked by JP	Date 11/02/15
----------------	------------------	------------------

Drawing Number OptimoHz15015	Revision
---------------------------------	----------

This drawing is the property of Kingspan and may not be reproduced in any way without written consent from Kingspan.