


Option C



Note: Secondary steelwork should be continuous, however if there is any gaps between the vertical supports which are above 20mm a flashing plate should be introduced to bridge the gap - refer to Kingspan Envirocare Update 49

Notes:

| | | | |
|--|--|--|--|
| | | | |
|--|--|--|--|

| Rev | Description | Chkd | Date |
|-----|-------------|------|------|
|-----|-------------|------|------|



Insulated Roof & Wall Panels



Kingspan Limited
Greenfield Business Park No. 2, Greenfield,
Holywell, Flintshire, CH8 7GJ, UK
www.kingspanpanels.co.uk
t: 0800 587 0090

Carrickmacross Road,
Kingscourt, Co.Cavan, Ireland
www.kingspanpanels.ie
t: 00353 42 96 98529

Client

Project

Drawing

KS1000 OPT Hz
Option A Vert Joint

Status

| | | |
|----------------|------------------|------------------|
| Drawn by RL | Checked by JP | Date 11/02/15 |
|----------------|------------------|------------------|

| | |
|---------------------------------|----------|
| Drawing Number OptimoHz15017 | Revision |
|---------------------------------|----------|

This drawing is the property of Kingspan and may not be reproduced in any way without written consent from Kingspan.