


Option D

Kingspan Horizontal Panel Vertical Support

Self-drilling self-tapping primary fixings with minimum 16mm diameter non-ferrous EPDM backed washer

SP4 push-in black EPDM gasket fitted before canister insualtion



Air seal - EPDM VJ1 bubble gasket 60x10mm

Site applied LPCB certified PIR insualtion board
any gaps filled with fire rated cannister insualtion

KS1000 Optimo / LPCB insulated wall panel horizontally laid

Note: Seconday steelwork should be continuous, however if there is any gaps between the vertical supports which are above 20mm a flashing plate should be introduced to brige the gap - refer to Kingspan Envirocare Update 49

Notes:

Rev	Description	Chkd	Date



Insulated Roof & Wall Panels

envirocare
TECHNICAL SERVICES

Kingspan Limited
Greenfield Business Park No. 2, Greenfield,
Holywell, Flintshire, CH8 7GJ, UK
www.kingspanpanels.co.uk
t: 0800 587 0090

Carrickmacross Road,
Kingscourt, Co.Cavan, Ireland
www.kingspanpanels.ie
t: 00353 42 96 98529

Client

Project

Drawing

**KS1000 OPT Hz
Option A Vert Joint**

Status

Drawn by RL	Checked by JP	Date 11/02/15
Drawing Number OptimoHz15018		Revision

This drawing is the property of Kingspan and may not be reproduced in any way without written consent from Kingspan.