





Option G



Flush insert



Recessed insert



MXG02 Rubber Gasket

Note: Secondary steelwork should be continuous, however if there is any gaps between the vertical supports which are above 20mm a flashing plate should be introduced to brige the gap - refer to Kingspan Envirocare Update 49

Notes:

Rev	Description	Chkd	Date



Insulated Roof & Wall Panels

envirocare
TECHNICAL SERVICES

Kingspan Limited
Greenfield Business Park No. 2, Greenfield,
Holywell, Flintshire, CH8 7GJ, UK
www.kingspanpanels.co.uk
t: 0800 587 0090

Carrickmacross Road,
Kingscourt, Co.Cavan, Ireland
www.kingspanpanels.ie
t: 00353 42 96 98529

Client

Project

Drawing

KS1000 AWP Hz
Option G Vertical Joint

Status

Drawn by	Checked by	Date
RL	JP	11/02/15

Drawing Number	Revision
OptimoHz15019	

This drawing is the property of Kingspan and may not be reproduced in any way without written consent from Kingspan.